

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0065:162 Page 1 of 1

CATEGORY: Audible Signal Devices

LISTEE: Faraday, 805 S. Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Models 6170, 6180, 6230, 6250 electronic horns; Models 6235 and 6255 horn strobes with suffix -E, -L, -M or -Z; Models 6175 and 6185 horn strobes with suffix -E or -L. Models with suffix -M or -Z are synchronized strobes and must be used with Models 5405 or 5406 sync module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: -E, -M (68cd)
-L, -Z (100cd)

INSTALLATION: In accordance with the listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as horns and horn/strobes for use with separately listed compatible fire alarm control units. These devices are not approved for the hearing impaired applications. Models are suitable for outdoor use when used with Model 3014 or 3015 back box.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Models 6170 and 6175 are for general signaling only and are not approved for use with fire alarm systems.

04-05-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager